

PERMIT FOR CONSTRUCTION OF SUBSURFACE SEWAGE DISPOSAL SYSTEM


228726

Issued to: <u>Seal, Greg</u> Owner, Developer, Contractor, Installer, Etc.	REGION <u>2</u>	COUNTY <u>78</u>	ID-NUMBER	DATE <u>06-12-89</u>
	STAFF <u>113</u>	INSTALLATION: ☒ 1. New Installation () 2. Repair to Existing System		
To be constructed by <u>Blalock</u> <u>no</u> (Installer) <u>City Sewer Available</u>	Type of System: ☒ 1. Standard () 3. Chapter 301 () 5. Other 2. Alternating () 4. Chapter 212			
Construction of a subsurface sewage disposal system is hereby authorized at: <u>1348 N. Baden Circle</u> <u>Lot 80 Lyndea BIK B Sec 1</u> (No. and street; Subdivision name and lot no.)	For: ☒ 1. Residential: No. B/R <u>3</u> () 2. Commercial/Industrial; Gal/Day _____			
Such a system shall consist of a septic tank of <u>900</u> gals. with <u>120</u> linear feet in <u>2</u> trenches, <u>96</u> inches wide, and <u>30</u> deep or _____	Evaluation based Upon: () 1. Soil Typing by Soil Scientist () 2. Soil Percolation Tests ☒ 3. Other <u>Permit is for approved S/D</u> Permeability Rate <u>lot without approved data.</u>			

The recipient of this permit agrees to construct or have constructed the system in accordance with the rules and regulations under the authority of TCA 53-2054. The recipient must notify the local health authority when the system is ready for inspection. If any part of system is covered before being inspected and approved, it shall be uncovered by the recipient of the permit at the direction of the local health authority.

Signature of Recipient-Owner, Developer, Contractor, Etc.: Ronnie Allen Date 12-21-88
Issued at Sevierville, Tennessee in the County of Sevier
By Sevier Co. Health Dept., D.G. Clayton Date 12-14-88
(Local Health Authority)

FOR INSPECTION, CALL 453-1032
OR 637-6853 BETWEEN 8:00 - 8:45 A.M.
INSTALL ON CONTOUR



----- Field Line
----- Solid Line
0 Depth in in.

Inspected By D.G. Clayton Local Health Authority
Date 06-12-89

Construction Approval: ☒ 1. Yes () 2. No

No. of Visits: 2

035

Time